



The Division of Information Technology
University Information Security Standards

NIST CONTROL FAMILY
IDENTIFICATION AND AUTHENTICATION CONTROLS

CONTROL NUMBER	CONTROL NAME	PRIORITY	REVIEW DATE
PE-15	Water Damage Protection	P1	07/23/2017

STATEMENT

WTAMU protects data center information systems from damage resulting from water leakage by providing master shutoff or isolation valves that are accessible, working properly, and known to key personnel within the facilities department (SSC).

I. APPLICABILITY

This Control applies to all West Texas A&M network information resources. The intended audience for this Control includes all information resource owners, custodians, and users of information resources.

II. IMPLEMENTATION

The University data center or other critical processing areas has a water shut-off valve if applicable.

